

KCL Number 1483-3

HEALTH APPROVAL

23726

RECEIVED

JUN 09 1983

107 EAST 100 SOUTH PROVO, UTAH 84601

Joseph K. Miner, UTAH COUNTY
Health Officer

PLANNING COMMISSION

CITY-COUNTY
HEALTH DEPARTMENT
OF UTAH COUNTY

PHONE 801-375-8100

BOARD OF HEALTH
Raymond C. Johnson, Chairman
Riley Clark, M.D.
Leonard H. Foote, M.D.
Keith J. Karran, Ph.D.
J. Wayne Nelson, Ed.D.
Keith J. Richen, Commissioner
Donald N. Wright, Ph.D.

June 9, 1983

Utah County Planning Commission
188 East Center
Provo, Utah 84601

Re: Pine Creek Subdivision
Lots 1-11, Plat B
Provo Canyon

1983 AUG - 8 PM 4:41
RECORDED AT THE REQUEST OF
Shandene
23726

Gentlemen:

Plans and supporting information on the water supply and wastewater disposal facilities for the above referred development have been submitted for our review as to the feasibility of supplying these services. The following comments reflect our review of the information submitted.

Wastewater Disposal Facilities

Based on soil information and percolation tests, it is our opinion that installation of subsurface wastewater disposal systems in this subdivision is feasible providing the following conditions are complied with:

1. Lots 9 and 11 have not had individual soil exploration and percolation tests conducted. Lots 9 and 11 will not be given in this subdivision unless the soil tests are satisfactory.
2. All lots must have plot plans approved by the health department. Because of the terrain of the area, an inspection for location of sewage system and building must be made by the health department before a building permit is issued. Once plot plans are approved, they must be strictly adhered to.
3. Approval of individual disposal systems will be given only after an inspection of each installation by a representative of the health department, following construction and installation, but prior to backfilling.
4. Each wastewater disposal system must be installed in compliance with the Utah State Department of Health "Code of Waste Disposal Regulations" Part IV, Individual Wastewater Disposal Systems.

8501 2069 146283

Utah County Planning Commission
Page 2
June 8, 1983

5. Subsurface wastewater disposal systems must be kept a minimum of 100 feet from any irrigation ditch, drain or underground drain.

Water Supply

The water supply to the Pine Creek Subdivision will be an extension of the North Fork Special Service District. This water supply is rated by the Utah State Bureau of Public Water Supplies as "not approved--corrective action." Progress must be made to correct the problems and be rated "approved."

It appears that sufficient water will be available at adequate pressure to serve the development (State Health Department letter dated March 11, 1983). Water lines should be disinfected according to the Utah State Division of Health publication "Disinfection of Public Water Supply Systems" or a AWWA Standard C601-68.

If you have any questions, please contact this office.

Sincerely,

CITY-COUNTY HEALTH DEPARTMENT
OF UTAH COUNTY

Glade S. Shelley

Glade S. Shelley, R.S.
Supervisor Environmental Health

GSS:dcp

Notary

Witness my hand and official
seal this 4th day of August,

City of Lehi
Lehi, Utah
Aug. 6-1-86

State of Utah, County of Utah:
On this 4th day of August, 1983,
personally appeared before me,
Glade S. Shelley, whose name is sub-
scribed to the foregoing Health
Approval and acknowledged to me
that he executed the same.

23726

BOOK 2069 PAGE 284